

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Exceptional International School of Education Vill. Sudhar Ajnala Amritsar
Exceptional International School of Education Vill. Sudhar Ajnala Amritsar

No.: RWTLASR/2627/00265 Dated : 18/05/2026

Subject : Testing Reports of Water Samples.


•Reference: Your Letter/SRF No. P434 Dated: 15/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/05/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



• Authorized Signatory
For, Regional Water Testing Lab
Amritsar



Principal
Exceptional International School of Education
Village:-Sudhar, Amritsar
Affiliated to C.B.S.E. Code:-1631470
School Code:-23683

TEST REPORT


Name & Address of Customer : Principal Exceptional International School of Education Vill. Sudhar Ajnala Amritsar Exceptional International School of Education Vill. Sudhar Ajnala Amritsar		Customer Reference No.	No : P434 Dated : 15/05/2026
		Sample Submitted by	Mr. Ajay
		Date of Sample Receipt	16/05/2026
		Analysis Starting Date	16/05/2026
		Analysis completion Date	18/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLASR/2627/00265	Date of Issue :	18/05/2026
Registration no.:	RWTLASR/REG2627/00878	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ajnala(S/pump 350 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.25@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	209	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.60@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	172	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	156	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	30.46	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	19.44	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By


Principal
Exceptional International School of Education
Village:-Sudhar, Amritsar
Affiliated to C.B.S.E. Code:-1631470
School Code:-23683


Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----