

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 985

Dated: 18/06/2026

It is certified that an inspection team headed by Mr. Khileshwar Sahu (S.D.O.)

(Name of Officers with designation) from Sub-Division Gauraspali PHED

inspected the "Sanskar The Rising School, Baraskal, B.A.S.N.A."

(Name & Address of the school) on 02/06/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. S.D.L./P.H.E.D./S.P.L.-105 dated 02/06/2026

of Sanskar Drinking Water (PHED Lab) certified that the

Sub-Divisional Water Testing Laboratory "Sanskar The Rising School Baraskal, B.A.S.N.A." (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till May 2027


Assistant Engineer

Signature with Seal: P.H. Engg. Sub-Division

Name Mr. Khileshwar Sahu

Designation Assistant Engineer

Name & Address of the Office / Department Sub-Division

Gauraspali Dist. Mahasamund.

To

Sanskar The Rising School,

Vit. Baraskal B.A.S.N.A.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Sub Divisional Water Testing Laboratory
Public Health Engineering Department, Sub Div. Saraipali
Near Tahasil office, Saraipali (C.G.) Pin Code-493558
Email ID – ae.phe.saraipali@gmail.com

Test Report (Drinking Water)				
Report no. SDL/PHED/SPL – 105		Discipline:- Chemical Testing	Group:-Drinking water	
Senders name & add Sanskar The Rising School Paraskol. Basna		Senders letter no./Date	-/01/06/26	Sampled by
		DL receipt no.	105	Customer
		Date of analysis started	2/06/26	Sampling Plan & procedure
		Date of analysis completed	2/06/26	Sampling not done by Lab staff
Sample Details				
S. N.	Sample ID	Block	City / Village	Habitation/Location/Source
1	105/06/26/202	Basna	Paraskol	Sanskar The Rising School Paraskol. Basna
2				
3				
4				
5				
6				

Details of parameters their test method units and specification as per IS/APHA

S.N	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 (Second Revision) Drinking water		Result of S.No					
		Method	Part no.		Acceptable limit	Permissible limit	1	2	3	4	5	6
1	2	3	4	5	6	7						
1	Chloride as Cl ⁻	APHA 23rd ed	4500-Cl-B	mg/L	250	1000	50.12	-	-	-	-	-
2	Total Dissolved solids	APHA 23rd ed	2540-C	mg/L	500	2000	300	-	-	-	-	-
3	Alkalinity as CaCO ₃	APHA 23rd ed	2320-B	mg/L	200	600	170.65	-	-	-	-	-
4	Calcium as Ca ²⁺	APHA 23rd ed	3500-Ca-B	mg/L	75	200	72.82	-	-	-	-	-
5	Magnesium as Mg ²⁺	APHA23rd ed.	3500 Mg-B	mg/L	30	100	5.86	-	-	-	-	-
6	pH	IS:3025	Part-11	pH scale	6.5-8.5	No relaxation	7.28	-	-	-	-	-
7	Turbidity	IS:3025	Part-10	NTU	1	5	0.0	-	-	-	-	-
8	Total Hardness as CaCO ₃	APHA 23rd ed	2340-C	mg/L	200	600	200.8	-	-	-	-	-
9	Taste	IS:3025	Part-8	-	Agreeable	Agreeable	-	-	-	-	-	-
10	Odour	IS:3025	Part-5	-	Agreeable	Agreeable	Agree	-	-	-	-	-
11	Color	APHA23rd ed.	2120-B	Hazen	5	15	2	-	-	-	-	-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. Samples will be stored for a period of 10 days from date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
6. Agreeable is denoted by Agr.

Note - 1. Results apply to the sample as received.

Report Reviewed & approved by

(Tekeshwari Chouhan)
Authorized Signatory

Sub Divisional Water Testing Laboratory
Public Health Engineering Department, Sub Div. Saraipali
Near Tahasil office, Saraipali (C.G.) Pin Code-493558

Test Report (Drinking Water)				
Report no. SDL/PHED/SPL – 105		Discipline:- Chemical Testing	Group:-Drinking water	
Senders name & add Sanskar The Rising School Paraskol. Basna		Senders letter no./Date	-/01/06/26	Sampled by
		DL receipt no.	105	Sampling Plan & procedure
		Date of analysis started	2/06/26	DL Receipt date
				Customer
Sampling not done by Lab staff				
Date of analysis completed				
2/06/26				

Sample Details				
S.N.	Sample ID	Block	City / Village	Habitation/Location/Source
1	105/06/26/202	Basna	Paraskol	Sanskar The Rising School Paraskol. Basna
2				
3				
4				
5				
6				

Details of parameters their test method units and specification as per IS/APHA												
S.N	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 (Second Revision) Drinking water		Result of S.No					
		Method			Acceptable limit	Permissible limit	1	2	3	4	5	6
1	2	3	4	5	6	7						
12	Fluoride as F ⁻	APHA 23rd ed	4500-F-C	mg/l.	1	1.5	0.25	-	-	-	-	-
13	Residual chlorine	-	-	mg/l.	0.2	1	-	-	-	-	-	-
14	E.coli	APHA:2024	9222-J	CFU/100 ml	Nil	Nil	-	-	-	-	-	-

- The report should not be produced partly or full without approval signatory authority of legal purpose.
 - It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
 - The results refer only to tested samples and parameters.
 - Samples will be stored for a period of 10 days from date of issue of report.
 - This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
 - Agreeable is denoted by Agr.
- Note - 1. Results apply to the sample as received.**


CHEMIST
Water testing Laboratory
P.H.E sub.Div. Saraipali (C.G)
for

Lab.Issue no....105.....Issue Date.....02/06/2026.....Page no...01.....of...01.....