

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 735

Dated: 10/09/2026

It is certified that an inspection team headed by Sumi Banjara

AEN Jahazpur (Name of Officers with designation)

from AEN PHED Sub Division Jahazpur PHED

inspected the Swami Vivekanand Govt. Model School, Jahazpur, Dist-Bhilwara

(Name & Address of the school) on 17/08/2026 (date of inspection) and on the basis of Water

Test Report (Attached) bearing no. dated.....

of AEN PHED Sub Division Office (PHED Lab)

certified that the Swami Vivekanand Govt. Model School, Jahazpur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal :

Sumi
सहायक अभियन्ता
20/8/2026

Name :

Designation :

Name & Address of the Office / Department :

To

Principal
Swami Vivekanand Govt. Model School (222590)
Jahazpur, Dist - Bhilwara (Raj) - 311201
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Public Health Engineering Department

District Laboratory



No.- PHED/Rout/Chem/2026-27/ 442

PHED Campus, Babu Nagar, Pur Road Bhilwara

Dated: 8/09/2026

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

Customer Name - Bhawar Lal Khatik Principal
Swami Vivekanand govt. Modern School
Jahazpur

District: Bhilwara
Block: Jahazpur

Reference : Bhawar Lal Khatik Principal Letter No.

Dated: 03.09.26

Lab Sample ID		Sample Descriptions			BIS 10500; 2012 Drinking Water Standards	
Panchayat / Town		DL-BHL/ 26-27/Rt/1318				
Village / Town		Jahazpur				
Habitation / Colony		Jahazpur				
Source		Pvt. Tank of RO Swami Vivekanand Govt. Model				
Date of Collection		03.09.26				
Name of Sample Taker		Ramdev Meena				
Date of Receipt		07.09.26				
Testing	Date	07.09.26 to 08.09.26				
Test Results						
SN	Parameter	Unit	Method	DL-BHL/ 26-27/Rt/1318	Maximum Desirable Limit	Maximum Permissible Limit
1	pH @ 25 °C		APHA 24th Edn.2023-4500-H B	7.41	6.5-8.5	NR
2	Conductivity @ 25 °C	µS/Cm	APHA 24th Edn.2023-2510 B	191	-	-
3	TDS	mg/L	APHA 24th Edn.2023-2540 C	128	500	2000
4	Chloride as Cl	mg/L	APHA 24th Edn.2023-4500-Cl- B	47	250	1000
5	Fluoride as F	mg/L	APHA 24th Edn.2023-4500-F C	0.15	1.0	1.5
6	Nitrate as NO3	mg/L	APHA 24th Edn.2023-4500 NO3-B UV	0.29	45	NR
7	Sulphate as SO4	mg/L	APHA 24th Edn.2023-4500 SO4- E	11.6	200	400
8	Total Alkalinity (as CaCO3)	mg/L	APHA 24th Edn.2023-2320 B	72	200	600
9	Total Hardness (as CaCO3)	mg/L	APHA 24th Edn.2023-2340 C	96	200	600
10	Calcium Hardness (as CaCO3)	mg/L	APHA 24th Edn.2023-3500-Ca B	45.0	188	500
11	Magnesium Hardness (as CaCO3)	mg/L	APHA 24th Edn.2023-3500-Mg B	51.00	122	412
12	Sodium as Na	mg/L	APHA 24th Edn.2023-3500 Na-B	8.90	-	-
13	Potassium as K	mg/L	APHA 24th Edn.2023-3500-K D	0.90	-	-
14	Turbidity	NTU	APHA 24th Edn.2023-2130 B	0.13	1	5

ND Not Detected

NA Not Analysed

Reviewed & Checked By
Junior Chemist

Dr. Ikbal Husain
Senior Chemist
PHED Lab Bhilwara

Note

- The results given above are related to the samples as received and tested in PHED District Lab Bhilwara
- The test report can't be regenerated/re-produced in whole or part thereof without written permission of PHED District Lab Bhilwara
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless and until specifically requested for retaining over a longer period.
- No monetary responsibility of the laboratory as no fee is charged for the analysis of test samples and issue of test report.
- Documents Related To MU are available in office and can be provided on request

----- End of Report -----

No. Lab / Tech (Bact.)/2026-27/ 446
To,

Dated - 08/09/2026

To,

Bhanwarlal Khatik
Swami Vivekanand Govt Model School
Jahazpur

Jahazpur

Report of Bacteriological Examination of Water

Reference: - Your Letter No. 0

Dated 07.09.26

Date of Receipt 07-Sep

Sample Taker Ramdev Meena

Method of Examination *IS 15185, 2016 Membrane Filter Technique*

[illegible]

Satisfactory

Unsat: - Unsatisfactory

Senior Chemist

PHED Dist. Lab BHILWARA

Dated

No. Lab / Tech (Bact.)/2025-26/

Copy to 1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur
2. Suprintending Chemist, PHED Regional Laboratory, Ajmer

Senior Chemist

PHED Dist. Lab BHILWARA