

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 04

Dated: 08/05/2026

It is certified that an inspection team headed by PRASHANT SHRIVASTAVA

(Name of Officers with designation) from Dist. WATER TESTING Lab PHED DATIA (M.P.)

inspected the SAI INTERNATIONAL SCHOOL INDARGARH

(Name & Address of the school) on 08/5/2026 (date of inspection) and on the basis of Water

Test Report (Attached) bearing no. dated 08/05/2026

of SAMPLE TESTED PHED Lab) certified that

the Sai International School INDARGARH (M.P.)

(Name of school) has safe drinking water facilities for the students and members of staff

of the institution. School is also maintains the hygienic sanitation condition in the school building &

the campus as per norms prescribed by the Central/ State/ U.T. Govt

This certificate is valid till 1 yrs.

Signature with Seal:

Name: PRASHANT SHRIVASTAVA

Designation: CHEMIST

Name & Address of the Office / Department

PHED - DATIA (M.P.)

To

SAI INTERNATIONAL School
Indargarh Datia (M.P.)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT WATER TESTING LABORATORY, PHED DATIA

(NATIONAL ACCREDITATION BOARD OF TESTING AND CALIBRATION LABORATORIES)

ISO/IEC 17025:2017

CERTIFICATE NUMBER: TC-16699

ANALYSIS-REPORT(2026-2027)

DISTRICT.....DATIA.....BLOCK.....DATIA.....

PARTICULARS OF SAMPLE

S.No.	City	Tahsil	Location	Source
1	Datia	Indergarh	Sai International School, Indergarh	T.W

Date of Collection - 07.05.2026 Date Receipt 07.05.2026 Date of Analysis 08.05.2026

Ref :- Sample collected by Customer

S.No.	Characteristics	Unit	Acceptable	Causes of Rejection	RESULTS				
					(1)	(2)	(3)	(4)	(5)

1.	PHYSICAL Temperature	oC	-	-	26				
2.	Turbidity	NTU	1.0	5.0	1.7				
3.	Colour	Pt/Co scale	5.0	15.0	01				
4.	Test & odour		Unobiecti on able	unob	Unob				

CHEMICAL

5.	PH		<6.5to8.5>	<6.5-8.5>	7.18				
6.	Conductivity	PH scale	-	-	272				
7.	Total Alkalinity		200 Mg/L	600 Mg/L	180				
8.	Chlorides	Mo.mhosh	250Mg/L	1000 Mg/L	38				
9.	Total Hardness as CaCO3		200 Mg/L	600 Mg/L	368				
10.	Calcium as Ca	Mg/L	75 Mg/L	200 Mg/L	48				
11.	Megnesium as Mg	Mg/L	30 Mg/L	100 Mg/L	32				
12.	Total Dissolved Solid	Mg/L	500 Mg/L	2000mg/L	436				
13.	Nitrate	Mg/L	45 Mg/L	45 Mg/L	16				
14.	Iron	Mg/L	1.0 Mg/L	No Relaxation	0.1				
15.	Fluorides	Mg/L	1.0 Mg/L	1.5 Mg/L	0.2				
16.	Sulphate	Mg/L	200	400 Mg/L	10				
17.	Manganese as Mn	Mg/L	0.1 Mg/L	0.3	NIL				
18.	Arsenic as as	Mg/L	0.01 Mg/L	No Relaxation	NIL				

BACTERIOLOGICAL-

19.	Total Coliform	Mg/L	NIL	NIL	nil				
	Faecalcoliform (TTC)	Mg/L	NIL	NIL	nil				

(Prashant Shrivastava)
Quality Manager

District water Testing Laboratory
PHED Datia