

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02

Dated: 09.04.2026

It is certified that an inspection team headed by Rupendra Singh

(Name of Officers with designation) from Assistant Engineer PHED Sayla

inspected the Swami Vivekanand govt model School Walera

(Name & Address of the school) on 09.04.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Spl-1 dated 09.04.2026

of ..... (PHED Lab) certified that

the Swami Vivekanand govt model School Walera Sayla (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 09.04.2029

Signature with Seal: सहायक अभियन्ता

Name जन. स्वा. अभि. विभाग

Designation जन. स्वा. अभि. विभाग

Name & Address of the Office/ Department : मु. प्र. वि. स. विभाग

To SWAMI VIVEKANAND  
GOVT. Model School Walera  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

### WATER SAMPLE TEST ANALYSIS REPORT

|                                 |                                                                                                    |                      |            |
|---------------------------------|----------------------------------------------------------------------------------------------------|----------------------|------------|
| Test Report No                  | SPL - 1                                                                                            | Sample ID            | 1          |
| Name & Address of Institution   | SWAMI VIVEKANAND GOVT MODEL SCHOOL WALERA<br>WALERA, BLOCK-SAYLA, DIST JALORE, RAJASTHAN<br>343022 |                      |            |
| Date of Sampling                | 09.04.2026                                                                                         | Date of Testing      | 09.04.2026 |
| Date of Sample Receipt          |                                                                                                    | Date of Report Issue | 09.04.2026 |
| Location of Sampling/Monitoring | Drinking Water/R.O. Product water                                                                  |                      |            |

#### Test Parameter Result

| Sr. No. | Parameter                           | Result       | IS: 10500,2012 Requirement (Acceptable Limit) | Unit      |
|---------|-------------------------------------|--------------|-----------------------------------------------|-----------|
| 1       | pH                                  | 7.2          | 6.5-8.5                                       | -         |
| 2       | Colour                              |              | 5                                             | Hazen     |
| 3       | Odour                               | Agreeable    | Agreeable                                     | -         |
| 4       | Taste                               | Agreeable    | Agreeable                                     | -         |
| 5       | Total Dissolved Solids              | 550          | 500                                           | mg/L      |
| 6       | Total Hardness as CaCO <sub>3</sub> | 220          | 200                                           | mg/L      |
| 7       | E-Coli                              | Not detected | Should not be detected                        | MPN/100ml |
| 8       | Total Coliforms                     | Not detected | Should not be detected                        | CFU/100ml |

25.  
सहायक अभियन्ता  
जन.स्वा.अभि.विभाग  
उप खण्ड सायला