

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. RWS - 131 - 2025 - 26.Dated: 21-7-2025.


It is certified that team headed by A. JAYARAMAPPA. A.E.E. RWS. Sub-on. Ranebennur.
(Name of officers with designation) from Ranebennur. PHED
inspected the **Dr. Kadkol Podar Learn School** at Survey No.36, Near Syngenta Seed Processing Unit
Asundi - Devargudda Road, Asundi Village, Taluka: Ranebennur, District: Haveri. State:
Karnataka on 21-7-2025 (date of inspection) and on the basis of Water Test Report
(Attached) bearing no 19-7-2025 dated (report details) found that **Dr. Kadkol
Podar Learn School** has safe drinking water facilities for the students and members of the institution.
School also maintains the hygienic sanitation condition in the school building & the campus as per the
norms prescribed by State/U. T Govt.

This certificate is valid till 20.06.2027

Signature with Seal: _____

Name: A. JAYARAMAPPA.Designation: A.E.E. RWS. Sub-on.Name & Address of Department/ Office: Ranebennur

To,
The Principal
Dr. Kadkol Podar Learn School
Survey No.36,
Near Syngenta Seed Processing Unit
Asundi - Devargudda Road Asundi Village,
Taluka: Ranebennur,
District: Haveri.
State: Karnataka


Manager
Dr. Kadkol Podar Learn School
Near Syngenta Seed Processing Unit,
Asundi - Devargudda Road, Asundi,
Ranebennur


Principal
Dr. Kadkol Podar Learn School
Near Syngenta Seed Processing Unit,
Asundi - Devargudda Road, Asundi,
Ranebennur



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District:Haveri

Sub Division: Ranebennur laboratory

TEST REPORT

Location : Dr.KADKOL PODAR LEARN SCHOOL, Near Syngenta Seed Processing Unit, Asundi Devaragudda Road, Asundi, Ranebennur					Report date: 19/07/2025
					Reference : Test Request Form
					Sample code: RAN24JULY
					Date of Sample collection: 18/07/2025
					Analysis start date: 18/07/2025
					Analysis completion date: 19/07/2025
					Sample collection protocol: IS 3025(Part-1)
Sample Particulars: RO (Drinking Water)					Sample quantity:1000ml
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colour less Sample					
1	pH @25.6 °C	7.34	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @ 25.9°C	122	–	–	IS 3025 (Part-14) : 2013
3	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) : 2021
4	Turbidity, NTU	0.05	1	5	IS 3025 (Part-10) : 2023
5	Total Dissolved Solids@ 179°C, mg/l	72	500	2000	IS 3025 (Part-16) : 2023
6	Alkalinity as CaCO_3 , mg/l	39.8	200	600	IS 3025 (Part-23) : 2023
7	Total Hardness as CaCO_3 , mg/l	68.06	200	600	IS 3025 (Part-21) : 2009
8	Calcium as Ca, mg/l	9.61	75	200	IS 3025 (Part-40) : 2024
9	Magnesium as Mg, mg/l	10.70	30	100	IS 3025 (Part-46) : 2023
10	Chloride as Cl, mg/l	49.98	250	1000	IS 3025 (Part-32) : 1988
11	Sulphate as SO_4 , mg/l	0.6	200	400	IS 3025 (Part-24) : 2022
12	Fluoride as F, mg/l	0.095	1	1.5	APHA 24 th Edition
13	Nitrate as NO_3 , mg/l	1.16	45	No relaxation	APHA 24 th Edition
14	Iron as Fe, mg/l	0.008	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample Conforms to the Acceptable/Permissible Limit of IS 10500 : 2012 RA:2018 Drinking Water Specification for The above tested parameter only.					
The Water Sample Safe to Drink					
Analysed by:			Verified by:		
Analyst : Hemamalini Hosamani			Assistant Executive Engineer		

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Manager

Dr. Kadkol Podar Learn School
Near Syngenta Seed Processing Unit,
Asundi - Devaragudda Road, Asundi,
Ranebennur

Principal

Dr. Kadkol Podar Learn School
Near Syngenta Seed Processing Unit,
Asundi - Devaragudda Road, Asundi,
Ranebennur